

**PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)**

2023 年 9 月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	894	185		846	165	
2	885	185		852	165	
3	889	186		850	165	
4	888	188		851	164	
5	890	187		851	165	
6	894	187		848	165	
7	894	187		845	164	
8	892	189		856	163	
9	893	192		856	163	
10	895	192		854	163	
11	885	191		849	164	
12	886	191		848	163	
13	884	191		853	164	
14	892	191		843	164	
15	894	191		848	164	
16	897	191		847	166	
17	886	191		855	167	
18	892	191		849	167	
19	887	189		856	166	
20	890	190		861	165	
21	887	189		862	164	
22	890	188		859	164	
23	890	188		855	165	
24	893	188		857	165	
25	894	187		860	165	
26	885	185		854	166	
27	887	186		853	166	
28	890	187		846	166	
29	894	187		850	166	
30	897	187		852	166	