

PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)

2025 年 7 月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	876	213		848	174	
2	875	228		839	174	
3	861	224		842	174	
4	871	221		844	174	
5	874	218		850	174	
6	865	215		844	174	
7	868	213		850	174	
8	872	210		858	173	
9	870	208		845	173	
10	-	-	14:40 ASD停止	859	174	
11	-	-		853	174	
12	-	-		841	174	
13	-	-		860	173	
14	-	-		851	173	
15	-	-		855	173	
16	-	-		864	174	
17	-	-		864	175	
18	-	-		856	174	
19	-	-		867	175	
20	-	-		872	174	
21	-	-		855	174	
22	-	-		854	175	
23	-	-		858	175	
24	-	-		871	175	
25	-	-		852	175	
26	-	-		845	174	
27	-	-		853	173	
28	-	-		842	173	
29	-	-		844	174	17:55 停止
30	-	-		-	-	
31	-	-		-	-	