

PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)

2025 年 9 月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	-	-		-	-	
2	-	-		-	-	
3	-	-		-	-	
4	-	-		-	-	
5	-	-		-	-	
6	-	-		-	-	
7	-	-		-	-	
8	-	-		-	-	
9	-	-		-	-	
10	-	-		-	-	
11	-	-		-	-	
12	-	-		-	-	
13	-	-		-	-	10:55運転
14	-	-		845	159	
15	-	-	10:00運転	875	162	
16	805	175		891	161	
17	818	185		923	162	
18	833	191		950	161	
19	826	199		849	159	
20	830	203		840	161	
21	830	204		836	164	
22	830	206		846	164	
23	833	208		851	163	
24	835	208		860	163	
25	842	209		862	162	
26	829	202		842	162	
27	820	188		851	162	
28	823	181		836	161	
29	828	182		843	159	
30	830	182		886	159	