

PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)

2025 年 11 月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	857	176		856	163	
2	860	176		859	162	
3	845	176		859	163	
4	851	177		872	163	
5	859	176		847	166	
6	862	176		852	166	
7	867	176		847	167	
8	869	177		880	167	
9	873	176		848	169	
10	860	177		844	170	
11	856	177		862	172	
12	859	177		860	164	
13	866	178		852	164	
14	862	178		852	165	
15	872	178		849	165	
16	871	178		850	165	
17	877	179		851	164	
18	865	178		850	165	
19	859	178		869	165	
20	860	177		865	165	
21	867	177		867	165	
22	871	179		859	164	
23	871	177		870	163	
24	867	177		874	165	
25	873	174		878	164	
26	877	176		877	163	
27	885	178		891	164	
28	898	181		887	164	
29	904	183		888	163	
30	889	193		881	164	