

PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)

2014 年 4 月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	874	188		865	169	
2	887	183		855	169	
3	891	183		858	169	
4	905	187		853	170	
5	884	187		858	169	
6	865	183		862	169	
7	874	183		861	170	
8	867	181		867	170	
9	878	183		864	170	
10	880	191		865	169	
11	886	189		861	170	
12	886	187		876	169	
13	887	190		875	168	
14	878	186		864	168	
15	880	185		865	168	
16	887	186		859	168	
17	888	185		871	168	
18	882	183		867	168	
19	877	182		865	169	
20	872	181		871	169	
21	874	180		866	169	
22	875	180		855	169	
23	877	180		850	169	
24	873	185		853	170	
25	874	191		853	170	
26	885	196		853	169	
27			STOP	868	169	
28				875	169	
29				873	169	
30				867	169	
31						