

**PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)**

2015年 3月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	888	210		864	169	
2	886	211		872	169	
3	894	214		868	170	
4	900	210		862	170	
5	906	204		871	170	
6	882	200		872	170	
7	877	198		874	170	
8	881	200		871	170	
9	873	197		850	171	
10	874	196		860	171	
11	876	198		874	171	
12	881	198		863	171	
13	887	199		869	170	
14	886	200		870	169	
15	891	201		875	169	
16	889	201		869	167	
17	886	199		865	167	
18	894	197		882	169	
19	900	194		889	168	
20	906	201		891	169	
21	898	201		884	169	
22	900	200		892	168	
23	895	192		887	167	
24	892	185		888	166	
25	890	184		883	166	
26	899	184		882	166	
27	883	185		867	167	
28	890	188		873	167	
29	899	186		876	167	
30	904	186		875	168	
31	909	187		874	167	