

PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)

2016年11月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	916	196		868	166	
2	922	207		863	166	
3	911	195		875	164	
4	909	194		881	164	
5	913	194		849	165	
6	910	194		853	164	
7	909	193		864	164	
8	914	192		861	165	
9	905	192		855	166	
10	909	192		859	168	
11	906	192		860	168	
12	908	193		853	168	
13	912	194		846	168	
14	916	194		856	167	
15	915	194		859	166	
16	909	194		851	167	
17	912	194		866	166	
18	914	193		855	166	
19	918	194		871	167	
20	918	195		856	167	
21	916	195		856	167	
22	916	193		854	167	
23	912	193		861	168	
24	912	191		873	167	
25	914	191		859	168	
26	914	191		860	167	
27	917	188		856	167	
28	916	189		853	167	
29	914	189		863	167	
30	914	189		861	167	