

**PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)**

2018年 3月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	916	211		851	167	
2	913	212		866	167	
3	914	212		879	167	
4	920	210		875	168	
5	911	207		865	168	
6	912	209		864	168	
7	918	210		878	169	
8	915	210		874	168	
9	916	208		860	168	
10	915	207		863	168	
11	921	208		881	166	
12	919	209		882	166	
13	919	210		887	167	
14	921	211		881	165	
15	919	212		879	166	
16	911	209		874	170	
17	912	209		866	172	
18	919	209		858	173	
19	920	210		859	173	
20	911	209		859	168	
21	913	208		866	168	
22	907	207		866	168	
23	908	207		873	168	
24	914	207		874	168	
25	907	209		867	168	
26	906	209		869	168	
27	908	210		871	168	
28	907	211		870	167	
29	908	210		875	167	
30	910	208		869	167	
31	920	209		862	167	