

PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)

2020年 2月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	919	194		917	171	
2	915	193		859	169	
3	920	194		859	169	
4	919	194		876	170	
5	916	193		863	172	
6	911	194		873	173	
7	915	194		869	172	
8	920	193		865	170	
9	920	192		874	169	
10	918	191		865	170	
11	915	190		869	170	
12	916	190		868	168	
13	913	190		868	166	
14	917	192		867	167	
15	912	192		884	167	
16	907	191		873	167	
17	903	191		863	168	
18	910	191		875	168	
19	910	190		867	168	
20	910	191		867	169	
21	912	192		862	169	
22	905	190		862	169	
23	897	190		860	169	
24	900	191		863	169	
25	900	192		866	169	
26	898	192		855	169	
27	901	191		863	169	
28	905	191		860	170	
29	911	191		858	170	