

PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)

2024 年 5 月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	873	185		848	171	
2	875	185		850	170	
3	882	185		851	169	
4	884	185		850	168	
5	886	185		850	168	
6	885	184		851	168	
7	886	184		850	168	
8	889	185		863	168	
9	891	184		865	168	
10	889	183		864	167	
11	893	184		851	168	
12	878	184		848	168	
13	869	178		867	168	
14	867	179		870	167	
15	876	181		871	167	
16	875	182		862	168	
17	874	181		864	165	
18	867	180		875	166	
19	869	178		894	167	
20	877	178		882	167	
21	874	176		892	167	
22	885	184		887	167	
23	870	213		878	167	
24	882	211		870	167	
25	875	200		868	167	
26	865	206		882	167	
27	868	206		886	167	
28	871	202		870	168	
29	884	206		888	168	
30	884	206		891	168	
31	872	197		888	168	