

PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)

2012年12月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	868	184		841	170	
2	867	188		838	171	
3	866	191		848	171	
4	885	192		859	170	
5	889	193		867	169	
6	890	195		860	170	
7	892	192		854	169	
8	886	191		855	169	
9	885	181		868	169	
10	872	179		853	169	
11	882	181		844	170	
12	870	178		864	170	
13	873	175		876	171	
14	875	174		857	171	
15	882	173		853	170	
16	882	176		853	169	
17	891	178		856	169	
18	895	179		874	167	
19	890	179		860	168	
20	888	180		866	168	
21	891	179		852	168	
22	888	180		842	168	
23	880	184		842	170	
24	884	185		832	171	
25	880	181		850	171	
26	886	180		849	171	
27	891	180		849	171	
28	894	181		844	171	
29	873	184		866	169	
30	875	187		870	168	
31	876	189		861	168	