

PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)

2013年 6月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	889	156		855	172	
2	895	161		859	172	
3	879	165		864	172	
4	881	156		878	171	
5	892	154		877	171	
6	892	154		862	172	
7	874	163		874	172	
8	881	172		880	172	
9	883	173		882	171	
10	890	173		877	171	
11	889	173		863	167	定修STOP
12	892	175				
13	883	170				
14	878	171				
15	883	174				
16	882	172				
17	891	176				
18	897	179				
19	876	177				
20	871	170				
21	888	173				
22	907	183				
23	905	188				
24	904	187				
25	901	187				
26	895	184				
27	899	184				
28	884	183				
29	904	182				
30	900	176				