

PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)

2014 年10月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	882	212		868	167	
2	884	214		855	167	
3	885	213		865	167	
4	888	209		850	168	
5	891	205		844	168	
6	885	203		849	168	
7	894	203		856	168	
8	886	199		868	168	
9	900	197		864	167	
10	901	200		856	168	
11	890	203		856	168	
12	887	201		864	168	
13	879	195		867	167	
14	888	199		871	168	
15	893	203		868	168	
16	874	203		871	167	
17	882	195		873	167	
18	885	195		873	166	
19	888	194		862	166	
20	888	193		873	166	
21	881	191		861	167	
22	896	195		848	168	
23	900	196		851	169	
24	885	196		854	169	
25	891	202		856	171	
26	900	196		848	172	
27	891	198		864	168	
28	891	197		874	167	
29	905	201		879	164	
30	913	203		875	165	
31	913	202		859	166	