

**PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)**

2016年 8月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	898	197		858	167	
2	916	200		856	167	
3	922	202		860	167	
4	913	202		861	167	
5	900	202		856	167	
6	914	202		863	166	
7	914	203		854	167	
8	909	203		872	166	
9	906	202		883	166	
10	912	205		880	166	
11	910	198		871	165	
12	907	198		863	164	
13	900	194		865	164	
14	900	195		852	164	
15	900	196		851	164	
16	893	196		854	164	
17	892	196		855	165	
18	899	196		856	165	
19	891	196		864	165	
20	896	198		862	166	
21	891	197		855	166	
22	895	201		858	166	
23	907	204		866	165	
24	906	205		872	164	
25	904	204		864	164	
26	906	204		854	164	
27	906	204		857	164	
28	905	204		856	164	
29	882	199		849	164	
30	883	198		860	163	
31	894	201		878	163	