

**PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)**

2017年 04月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	920	200		862	171	
2	925	197		856	170	
3	922	193		860	170	
4	923	190		858	170	
5	924	188		863	169	
6	923	189		866	169	
7	919	190		863	169	
8	917	190		858	170	
9	916	188		858	170	
10	915	189		861	170	
11	922	190		870	172	
12	918	190		866	172	
13	916	192		864	172	
14	912	186		865	172	
15	915	193		864	172	
16	919	194		854	172	
17	920	194		854	171	
18	921	193		860	171	
19	918	193		869	171	
20	918	192		862	171	
21	915	192		863	171	
22	916	193		860	171	
23	915	193		864	171	
24	919	193		866	171	
25	921	189		869	171	
26	913	187		853	171	
27	911	201		861	171	
28	914	201		861	171	
29	912	201		861	171	
30	914	203		855	172	
31						