

PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)

2017年 8月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	892	187		872	163	
2	907	188		873	162	
3	918	192		875	162	
4	919	190		864	163	
5	905	195		863	164	
6	895	197		857	164	
7	887	193		871	164	
8	893	195		862	165	
9	897	197		854	165	
10	898	196		860	161	
11	898	195		867	161	
12	896	194		868	162	
13	892	194		872	163	
14	892	195		862	164	
15	894	196		861	164	
16	894	195		871	164	
17	902	196		865	163	
18	904	196		868	162	
19	902	196		865	162	
20	900	196		856	164	
21	900	197		852	164	
22	899	198		867	164	
23	905	199		860	165	
24	903	199		858	165	
25	902	200		855	165	
26	902	200		859	165	
27	907	200		854	165	
28	905	200		861	164	
29	907	200		859	164	
30	909	200		866	164	
31	915	199		873	162	