

PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)

2017年 9月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	900	199		874	161	
2	899	199		861	162	
3	900	199		867	162	
4	905	200		871	162	
5	906	200		873	162	
6	904	199		872	162	
7	907	195		856	163	
8	893	192		863	162	
9	900	193		875	164	
10	897	194		875	164	
11	900	194		858	164	
12	900	193		867	164	
13	900	194		863	164	
14	903	196		863	164	
15	897	197		869	164	
16	895	194		887	163	
17	901	193		865	163	
18	898	194		867	163	
19	898	194		864	163	
20	899	194		876	163	
21	896	194		870	163	
22	895	195		874	163	
23	895	195		868	163	
24	899	195		863	164	
25	905	196		868	163	
26	908	197		866	164	
27	909	198		859	164	
28	907	194		868	163	
29	898	194		874	163	
30	897	196		876	163	