

PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)

2018年 02月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	918	201		882	170	
2	920	204		876	169	
3	913	205		864	168	
4	912	204		865	167	
5	911	202		866	167	
6	905	201		872	166	
7	904	200		880	165	
8	906	200		877	165	
9	911	200		869	166	
10	911	200		874	166	
11	909	200		873	166	
12	904	200		862	168	
13	907	200		868	168	
14	901	202		869	168	
15	903	203		877	167	
16	906	205		881	167	
17	906	207		875	167	
18	906	209		874	167	
19	910	209		870	167	
20	909	209		874	167	
21	907	210		873	167	
22	909	210		870	167	
23	917	212		877	166	
24	918	215		882	166	
25	914	213		879	165	
26	916	213		881	165	
27	922	213		859	168	
28	922	213		856	167	