

PH・MMA廃棄物焼却炉運転温度(炉内、廃熱ボイラー出口)

2018年 12月度

日	PH廃棄物焼却炉			MMA廃棄物焼却炉		
	炉内温度 ℃	ボイラー出口温度 ℃	備考	炉内温度 ℃	ボイラー出口温度 ℃	備考
1	905	199		869	167	
2	908	199		871	167	
3	906	200		875	166	
4	907	201		871	168	
5	899	201		878	168	
6	905	201		876	168	
7	909	202		866	168	
8	917	202		866	168	
9	913	201		873	168	
10	912	199		884	164	
11	917	198		875	164	
12	912	197		876	166	
13	915	198		878	167	
14	911	199		878	167	
15	916	197		874	168	
16	921	194		880	168	
17	918	193		867	169	
18	923	195		871	169	
19	920	196		871	168	
20	913	196		873	168	
21	909	196		882	168	
22	902	195		880	168	
23	908	195		873	168	
24	907	195		868	168	
25	908	195		882	166	
26	909	195		873	166	
27	906	196		871	167	
28	915	187		882	167	
29	918	183		896	167	
30	904	190		886	167	
31	911	186		880	168	